



Product designation Product type designation			Power contactor BF12
Contact characteristics			
Number of poles		nr.	4
Rated insulation voltage Ui		V	690
Rated impulse withstand voltage Uimp		kV	6
Operating frequency			
	Operational frequency min	Hz	25
	Operational frequency max	Hz	400
Conventional free air thermal current Ith		Α	28
Operating current			
	Operational current AC1 (≤40°C)	Α	28
Opera	ational current AC3 (≤440V ≤55°C)	Α	12
	Operational current AC4 (400V)	Α	7.9
Rated operational power AC1 (T≤40°C)			
	230V	kW	10
	400V	kW	18
	500V	kW	23
	690V	kW	32
Rated operational power AC3 (T≤55°C)			
	230V	kW	3.2
	400V	kW	5.7
	415V	kW	6.2
	440V	kW	6.2
	500V	kW	7.5
	690V	kW	10
Short-time allowable current for 10s (IEC/EN60947-1)		Α	150
Protection fuse			
	gG (IEC)	Α	32
	aM (IEC)	Α	12
Making capacity (RMS value)		Α	120
Breaking capacity at voltage			
	Breaking capacity 440V	Α	96
	Breaking capacity 500V	Α	96
	Breaking capacity 690V	Α	94
Resistance per pole (average value)		mΩ	2.5
Power dissipation per pole (average value)			
Power	dissipation pole (average value) Ith	W	2
	AC3	W	0.4
Tightening torque for terminals			
	min	Nm	1.5
	max	Nm	1.8
	min	lbft	1.1
	max	lbft	1.5



		min	Nm	0.8
		max	Nm	1
		min	lbft	0.8
		max	lbft	0.74
max number of wires	simultaneously connectable		nr.	2
Conductor section				
	AWG			
		min		16
		max		10
	Flexible w/o lug conductor section			
	-	min	mm²	1
		max	mm²	6
	Flexible c/w lug conductor section			
	ŭ	min	mm²	1
		max	mm²	4
	Flexible with insulated spade lug conductor section	n		
		min	mm²	1
		max	mm²	4
Power terminal protect	ction according to IEC/EN 60529			IP20 when wired
Auxiliary contact chara				ii 20 Wilon Wilod
Operational current A			Α	28
Operating current DC				
Operating current bo	10			Screw / DIN rail
		110V	Α	35mm
Ambient conditions				Oomin
Temperature				
remperature	Operating temperature			
	Operating temperature	min	°C	-50
			°C	70
	Storage temperature	max	<u> </u>	70
	Storage temperature	min	°C	-60
		min	°C	
Marratituda		max		80
Max altitude			m	3000
Operating position				
		normal		Vertical plan
		allowable		±30°
Mounting				Screw / DIN rail
				35mm
Weight			g	0.366
Operations				
Mechanical life			Cycles	20000000
Electrical life			Cycles	2000000
Safety related data				
Performance level B1	0d according to EN/ISO 13489-1			
		rated load	Cicli	2000000
		mechanical load	Cicli	20000000
	ing to IEC/EN 609474-4-1			yes
EMC compatibility				yes
AC coil operating				
AC operating voltage				
-	of 50/60Hz coil powered at 50Hz			
	pick-up			
	·	min	%Us	0.8





		max	%Us	1.1
	drop-out	max	7003	1.1
	diop out	min	%Us	0.2
		max	%Us	0.55
	of 50/60Hz coil powered at 60Hz	max	7003	0.00
	pick-up			
	ριοκ αρ	min	%Us	0.85
		max	%Us	1.1
	drop-out	max	7000	
	arop cut	min	%Us	0.2
		max	%Us	0.55
	of 60Hz coil powered at 60Hz	max	7000	0.00
	pick-up			
	pion up	min	%Us	0.8
		max	%Us	1.1
	drop-out		,,,,,	
	2. Jp 04.	min	%Us	0.2
		max	%Us	0.55
AC operating voltage		iii an		
operating voltage	of 50/60Hz coil powered at 50Hz			
	of 30/00112 con powered at 30112	in-rush	VA	75
		holding	VA	9
	of 50/60Hz coil powered at 60Hz	Holding	٧, ١	
	of 30/00112 con powered at our iz	in-rush	VA	70
		holding	VA	6.5
	of 60Hz coil powered at 60Hz	Holding	٧, ١	0.0
	or our iz con powered at our iz	in male	VA	75
		in-riish		
		in-rush holding		
Dissination at holding	<20°C 50Hz	in-rush holding	VA	9
Dissipation at holding	≤20°C 50Hz			
Max cycles frequency		holding	VA W	9 2.5
Max cycles frequency Mechanical operations		holding	VA	9 2.5
Max cycles frequency Mechanical operations Operating times		holding	VA W	9 2.5
Max cycles frequency Mechanical operations	ontrol	holding	VA W	9 2.5
Max cycles frequency Mechanical operations Operating times	ontrol in AC	holding	VA W	9 2.5
Max cycles frequency Mechanical operations Operating times	ontrol	holding	VA W Cycles/h	9 2.5 3600
Max cycles frequency Mechanical operations Operating times	ontrol in AC	holding	VA W Cycles/h	9 2.5 3600
Max cycles frequency Mechanical operations Operating times	ontrol in AC Closing NO	holding	VA W Cycles/h	9 2.5 3600
Max cycles frequency Mechanical operations Operating times	ontrol in AC	holding min max	VA W Cycles/h ms ms	9 2.5 3600 8 24
Max cycles frequency Mechanical operations Operating times	ontrol in AC Closing NO	min max	VA W Cycles/h ms ms	9 2.5 3600 8 24 10
Max cycles frequency Mechanical operations Operating times	ontrol in AC Closing NO Opening NO	holding min max	VA W Cycles/h ms ms	9 2.5 3600 8 24
Max cycles frequency Mechanical operations Operating times	ontrol in AC Closing NO	min max min max	VA W Cycles/h ms ms	9 2.5 3600 8 24 10 20
Max cycles frequency Mechanical operations Operating times	ontrol in AC Closing NO Opening NO	min max min max	VA W Cycles/h ms ms ms ms	9 2.5 3600 8 24 10 20
Max cycles frequency Mechanical operations Operating times	ontrol in AC Closing NO Opening NO Closing NC	min max min max	VA W Cycles/h ms ms	9 2.5 3600 8 24 10 20
Max cycles frequency Mechanical operations Operating times	ontrol in AC Closing NO Opening NO	min max min max min max	VA W Cycles/h ms ms ms ms ms	9 2.5 3600 8 24 10 20 14 28
Max cycles frequency Mechanical operations Operating times	ontrol in AC Closing NO Opening NO Closing NC	min max min max min max min max	MS	9 2.5 3600 8 24 10 20 14 28
Max cycles frequency Mechanical operations Operating times Average time for Us of	ontrol in AC Closing NO Opening NO Closing NC	min max min max min max	VA W Cycles/h ms ms ms ms ms	9 2.5 3600 8 24 10 20 14 28
Max cycles frequency Mechanical operations Operating times Average time for Us of	ontrol in AC Closing NO Opening NO Closing NC Opening NC	min max min max min max min max	MS	9 2.5 3600 8 24 10 20 14 28
Max cycles frequency Mechanical operations Operating times Average time for Us of	ontrol in AC Closing NO Opening NO Closing NC	min max min max min max min max	W Cycles/h ms ms ms ms ms ms ms	9 2.5 3600 8 24 10 20 14 28 7 18
Max cycles frequency Mechanical operations Operating times Average time for Us of	ontrol in AC Closing NO Opening NO Closing NC Opening NC	min max min max min max at 480V	WCycles/h	9 2.5 3600 8 24 10 20 14 28 7 18
Max cycles frequency Mechanical operations Operating times Average time for Us of UL technical data Full-load current (FLA)	ontrol in AC Closing NO Opening NO Closing NC Opening NC Opening NC	min max min max min max min max	W Cycles/h ms ms ms ms ms ms ms	9 2.5 3600 8 24 10 20 14 28 7 18
Max cycles frequency Mechanical operations Operating times Average time for Us of	ontrol in AC Closing NO Opening NO Closing NC Opening NC Opening NC	min max min max min max at 480V	WCycles/h	9 2.5 3600 8 24 10 20 14 28 7 18
Max cycles frequency Mechanical operations Operating times Average time for Us of UL technical data Full-load current (FLA)	ontrol in AC Closing NO Opening NO Closing NC Opening NC Opening NC	min max min max min max at 480V at 600V	W Cycles/h ms ms ms ms ms ms A A	9 2.5 3600 8 24 10 20 14 28 7 18
Max cycles frequency Mechanical operations Operating times Average time for Us of UL technical data Full-load current (FLA)	ontrol in AC Closing NO Opening NO Closing NC Opening NC Opening NC	min max min max min max at 480V	WCycles/h	9 2.5 3600 8 24 10 20 14 28 7 18



for three-phase AC motor			
, , , , , , , , , , , , , , , , , , ,	at 200/208V	hp	5
	at 220/230V	hp	5
	at 460/480V	hp	7.5
	at 575/600V	hp	10

General USE


Contactor

AC current A 28 Other features


Office readures

Pollution degree 3

Dimensions



Wiring diagrams



Certifications and compliance

Certifications

CSA C22.2 n° 60947-1

CSA C22.2 n° 60947-4-1

IEC/EN 60947-1

IEC/EN 60947-4-1



ENERGY AND AUTOMATION

Compliance

BF12T4A400

FOUR-POLE CONTACTOR, IEC OPERATING CURRENT ITH (AC1) = 28A, AC COIL 50/60HZ,

UL 60947-1	
UL 60947-4-1	
CCC	
cULus	
EAC	

ETIM 6 classification

EC000066 - Power contactor, AC switching