



Product designation			Power contactor
Product type designation			BF18
Contact characteristics			
Number of poles		nr.	4
Rated insulation voltage Ui		V	690
Rated impulse withstand voltage Uimp		kV	6
Operating frequency			
	erational frequency min	Hz	25
·	erational frequency max	Hz	400
Conventional free air thermal current Ith	erational frequency max	A	32
Operating current			32
, •	nal current AC1 (≤40°C)	۸	32
•	,	A	
•	ent AC3 (≤440V ≤55°C)	A	18
·	onal current AC4 (400V)	Α	8.5
Rated operational power AC1 (T≤40°C)	0001/	1.347	10
	230V	kW	12
	400V	kW	21
	500V	kW	26
	690V	kW	36
Rated operational power AC3 (T≤55°C)			
	230V	kW	4
	400V	kW	7.5
	415V	kW	9
	440V	kW	9
	500V	kW	10
	690V	kW	10
Short-time allowable current for 10s (IEC/EN60947-1)		Α	200
Protection fuse			
	gG (IEC)	Α	32
	aM (IEC)	Α	20
Making capacity (RMS value)		Α	180
Breaking capacity at voltage			
	Breaking capacity 440V	Α	144
	Breaking capacity 500V	Α	120
	Breaking capacity 690V	Α	94
Resistance per pole (average value)	<u> </u>	mΩ	2.5
Power dissipation per pole (average value)			
	pole (average value) Ith	W	2.6
1 on or alcorpution	AC3	W	0.8
Tightening torque for terminals	7.00	••	3.0
Tightoning torque for terminate	min	Nm	1.5
	max	Nm	1.8
	min	lbft	1.0
		lbft	1.5
Tightening torque for coil terminal	max	וטונ	1.0

Tightening torque for coil terminal



		min	Nm	0.8
		max	Nm	1
		min	lbft	0.8
		max	lbft	0.74
max number of wires	simultaneously connectable		nr.	2
Conductor section				
	AWG			
		min		16
		max		10
	Flexible w/o lug conductor section			
		min	mm²	1
		max	mm²	6
	Flexible c/w lug conductor section			
		min	mm²	1
		max	mm²	4
	Flexible with insulated spade lug conductor section			
		min	mm²	1
		max	mm²	4
	ction according to IEC/EN 60529			IP20 when wired
Auxiliary contact char				
Operational current A			Α	32
Operating current DC	13			
		110V	Α	Screw / DIN rail
				35mm
Ambient conditions				
Temperature				
	Operating temperature			
		min	°C	-50
	-	max	°C	70
	Storage temperature		20	
		min	°C	-60
		max	°C	80
Max altitude			m	3000
Operating position				
		normal		Vertical plan
		allowable		±30°
Mounting				Screw / DIN rail
\\\\a\:\a\:\a\:\				35mm
Weight			g	0.366
Operations Mechanical life			Cycles	20000000
Electrical life			Cycles	20000000 1600000
			Cycles	1600000
Safety related data	10d apparding to EN/ISO 42490 4			
renormance level B1	10d according to EN/ISO 13489-1	wata -l lo - 1	0:-"	4000000
		rated load	Cicli	1600000
Minnen contata assist		anical load	Cicli	20000000
	ing to IEC/EN 609474-4-1			yes
EMC compatibility				yes
AC coil operating				
AC operating voltage				
	of 50/60Hz coil powered at 50Hz			
	pick-up		0/11-	0.0
		min	%Us	0.8





		max	%Us	1.1
	drop-out			
	·	min	%Us	0.2
		max	%Us	0.55
	of 50/60Hz coil powered at 60Hz			
	pick-up			
		min	%Us	0.85
		max	%Us	1.1
	drop-out			
		min	%Us	0.2
		max	%Us	0.55
	of 60Hz coil powered at 60Hz			
	pick-up			
		min	%Us	0.8
		max	%Us	1.1
	drop-out			
	·	min	%Us	0.2
		max	%Us	0.55
AC operating voltage				_
, 5 3	of 50/60Hz coil powered at 50Hz			
		in-rush	VA	75
		holding	VA	9
	of 50/60Hz coil powered at 60Hz	<u> </u>		
		in-rush	VA	70
		holding	VA	6.5
	of 60Hz coil powered at 60Hz			
	o. oo oo. poou a. oo	:	VA	75
		in-rusn	V /	
		in-rush holdina		
Dissipation at holding:	≤20°C 50Hz	holding	VA	9
Dissipation at holding:	≤20°C 50Hz			
Max cycles frequency		holding	VA W	9 2.5
Max cycles frequency Mechanical operations		holding	VA	9 2.5
Max cycles frequency Mechanical operations Operating times		holding	VA W	9 2.5
Max cycles frequency Mechanical operations	ontrol	holding	VA W	9 2.5
Max cycles frequency Mechanical operations Operating times	ontrol in AC	holding	VA W	9 2.5
Max cycles frequency Mechanical operations Operating times	ontrol	holding	VA W Cycles/r	9 2.5 3600
Max cycles frequency Mechanical operations Operating times	ontrol in AC	holding	VA W	9 2.5 3600
Max cycles frequency Mechanical operations Operating times	ontrol in AC Closing NO	holding	VA W Cycles/h	9 2.5 3600
Max cycles frequency Mechanical operations Operating times	ontrol in AC	holding	VA W Cycles/h	9 2.5 3600
Max cycles frequency Mechanical operations Operating times	ontrol in AC Closing NO	holding min max	VA W Cycles/r ms ms	9 2.5 3600 8 24
Max cycles frequency Mechanical operations Operating times	ontrol in AC Closing NO	min max	VA W Cycles/r ms ms	9 2.5 3600 8 24 10
Max cycles frequency Mechanical operations Operating times	ontrol in AC Closing NO Opening NO	min max	VA W Cycles/r ms ms	9 2.5 3600 8 24 10
Max cycles frequency Mechanical operations Operating times	ontrol in AC Closing NO Opening NO	min max min max	VA W Cycles/r ms ms	9 2.5 3600 8 24 10 20
Max cycles frequency Mechanical operations Operating times	ontrol in AC Closing NO Opening NO	min max min max	WCycles/rms ms ms ms ms	9 2.5 3600 8 24 10 20
Max cycles frequency Mechanical operations Operating times	ontrol in AC Closing NO Opening NO Closing NC	min max min max	WCycles/rms ms ms ms ms	9 2.5 3600 8 24 10 20
Max cycles frequency Mechanical operations Operating times	ontrol in AC Closing NO Opening NO Closing NC	min max min max min max	VA W Cycles/h ms ms ms ms ms	9 2.5 3600 8 24 10 20 14 28
Max cycles frequency Mechanical operations Operating times	ontrol in AC Closing NO Opening NO Closing NC	min max min max min max min max	MS	9 2.5 3600 8 24 10 20 14 28
Max cycles frequency Mechanical operations Operating times Average time for Us co	ontrol in AC Closing NO Opening NO Closing NC	min max min max min max min max	MS	9 2.5 3600 8 24 10 20 14 28
Max cycles frequency Mechanical operations Operating times Average time for Us co	ontrol in AC Closing NO Opening NO Closing NC Opening NC	min max min max min max min max	MS	9 2.5 3600 8 24 10 20 14 28
Max cycles frequency Mechanical operations Operating times Average time for Us co	ontrol in AC Closing NO Opening NO Closing NC Opening NC	min max min max min max min max	W Cycles/h ms ms ms ms ms ms	9 2.5 3600 8 24 10 20 14 28 7 18
Max cycles frequency Mechanical operations Operating times Average time for Us co	ontrol in AC Closing NO Opening NO Closing NC Opening NC Opening NC	min max min max min max at 480V	WCycles/r	9 2.5 3600 8 24 10 20 14 28 7 18
Max cycles frequency Mechanical operations Operating times Average time for Us co	ontrol in AC Closing NO Opening NO Closing NC Opening NC Opening NC	min max min max min max at 480V	WCycles/r	9 2.5 3600 8 24 10 20 14 28 7 18
Max cycles frequency Mechanical operations Operating times Average time for Us co	ontrol in AC Closing NO Opening NO Closing NC Opening NC Opening NC	min max min max min max at 480V	W Cycles/h ms ms ms ms ms ms A A	9 2.5 3600 8 24 10 20 14 28 7 18
Max cycles frequency Mechanical operations Operating times Average time for Us co	ontrol in AC Closing NO Opening NO Closing NC Opening NC Opening NC	min max min max min max at 480V at 600V	WCycles/r	9 2.5 3600 8 24 10 20 14 28 7 18



for three-phase AC motor			
•	at 200/208V	hp	5
	at 220/230V	hp	5
	at 460/480V	hp	10
	at 575/600V	hp	15

General USE


Contactor

AC current A 32


Other features

Pollution degree 3

Dimensions



Wiring diagrams



Certifications and compliance

Certifications

CSA C22.2 n° 60947-1

CSA C22.2 n° 60947-4-1

IEC/EN 60947-1

IEC/EN 60947-4-1



ENERGY AND AUTOMATION

BF18T4A024

FOUR-POLE CONTACTOR, IEC OPERATING CURRENT ITH (AC1) = 32A, AC COIL 50/60HZ,

	UL 60947-1	
	UL 60947-4-1	
Compliance		
	CCC	
	cULus	
	EAC	

ETIM 6 classification

EC000066 - Power contactor, AC switching