DATASHEET - FAZ-D32/4



Miniature circuit breaker (MCB), 32A, 4p, D-Char, AC

Powering Business Worldwide*

Part no. FAZ-D32/4 Catalog No. 279087 Alternate Catalog FAZ-D32/4

No.

EL-Nummer 0001695243

(Norway)

Similar to illustration

Delivery program

Delivery program			
Basic function			Miniature circuit-breakers
Number of poles			4 pole
Tripping characteristic			D
Application			Switchgear for industrial and advanced commercial applications
Rated current	In	Α	32
Rated switching capacity acc. to IEC/EN 60947-2	I _{cu}	kA	15
Product range			FAZ

Technical data

ectrica	

Standards			IEC/EN 60947-2 IEC/EN 60898
Rated operational voltage	U _e	V	
	U _e	V AC	240/415
		V DC	60 (per pole)
Rated switching capacity acc. to IEC/EN 60947-2	I _{cu}	kA	15
Operational switching capacity		kA	7.5
Characteristic			B, C, D, K, S, Z
Max. back-up fuse		A gL/gG	125
Selectivity Class			3
ifespan			
Lifespan	Operations		> 10000
Direction of incoming supply			as required
<i>N</i> echanical			
Standard front dimension		mm	45
inclosure height		mm	80
Mounting width per pole		mm	17.5
Mounting			IEC/EN 60715 top-hat rail
Degree of Protection			IP20, IP40 (when fitted)
Ferminals top and bottom			Twin-purpose terminals
Ferminal protection			Finger and back-of-hand proof to BGV A2
Ferminal capacities		mm^2	
		mm^2	1 x 25
		mm ²	2 x 10
hickness of busbar material		mm	0.8 2
Mounting position			As required

Design verification as per IEC/EN 61439

Technical data for design verification			
Rated operational current for specified heat dissipation	In	Α	32
Heat dissipation per pole, current-dependent	P _{vid}	W	0
Equipment heat dissipation, current-dependent	P _{vid}	W	13.6

Static heat dissipation, non-current-dependent	P_{vs}	W	0
Heat dissipation capacity	P _{diss}	W	0
Operating ambient temperature min.		°C	-40
Operating ambient temperature max.		°C	75
			linear, per +1 °C, results in a 0.5% reduction of current carrying capacity
IEC/EN 61439 design verification			
10.2 Strength of materials and parts			
10.2.2 Corrosion resistance			Meets the product standard's requirements.
10.2.3.1 Verification of thermal stability of enclosures			Meets the product standard's requirements.
10.2.3.2 Verification of resistance of insulating materials to normal heat			Meets the product standard's requirements.
10.2.3.3 Verification of resistance of insulating materials to abnormal heat and fire due to internal electric effects $\frac{1}{2} = \frac{1}{2} \left(\frac{1}{2} + \frac{1}{2} \right) \left(\frac{1}{2} + \frac{1}{2} + \frac{1}{2} \right) \left(\frac{1}{2} + \frac{1}$			Meets the product standard's requirements.
10.2.4 Resistance to ultra-violet (UV) radiation			Meets the product standard's requirements.
10.2.5 Lifting			Does not apply, since the entire switchgear needs to be evaluated.
10.2.6 Mechanical impact			Does not apply, since the entire switchgear needs to be evaluated.
10.2.7 Inscriptions			Meets the product standard's requirements.
10.3 Degree of protection of ASSEMBLIES			Does not apply, since the entire switchgear needs to be evaluated.
10.4 Clearances and creepage distances			Meets the product standard's requirements.
10.5 Protection against electric shock			Does not apply, since the entire switchgear needs to be evaluated.
10.6 Incorporation of switching devices and components			Does not apply, since the entire switchgear needs to be evaluated.
10.7 Internal electrical circuits and connections			Is the panel builder's responsibility.
10.8 Connections for external conductors			Is the panel builder's responsibility.
10.9 Insulation properties			
10.9.2 Power-frequency electric strength			Is the panel builder's responsibility.
10.9.3 Impulse withstand voltage			Is the panel builder's responsibility.
10.9.4 Testing of enclosures made of insulating material			Is the panel builder's responsibility.
10.10 Temperature rise			The panel builder is responsible for the temperature rise calculation. Eaton will provide heat dissipation data for the devices.
10.11 Short-circuit rating			Is the panel builder's responsibility. The specifications for the switchgear must be observed.
10.12 Electromagnetic compatibility			Is the panel builder's responsibility. The specifications for the switch gear must be observed. $\label{eq:constraint}$
10.13 Mechanical function			The device meets the requirements, provided the information in the instruction leaflet (IL) is observed.

Technical data ETIM 7.0

Over voltage category

Pollution degree

Circuit breakers and fuses (EG000020) / Miniature circuit breaker (MCB) (EC000042)


Electric engineering, automation, process control engineering / Electrical installation, device / Miniature circuit breaker system (MCB) / Miniature circuit breaker (MCB) (ecl@ss10.0.1-27-14-19-01 [AAB905014]) Release characteristic D Number of poles (total) 4 4 Number of protected poles Rated current Α 32 ٧ 400 Rated voltage Rated insulation voltage Ui ٧ 440 kV 4 Rated impulse withstand voltage Uimp Rated short-circuit breaking capacity Icn EN 60898 at 230 V kΑ 10 Rated short-circuit breaking capacity Icn EN 60898 at 400 V kΑ 10 Rated short-circuit breaking capacity Icu IEC 60947-2 at 230 V kΑ 15 Rated short-circuit breaking capacity Icu IEC 60947-2 at 400 V $\,$ kA 15 Voltage type AC Hz 50 - 60 Frequency **Current limiting class** 3 Suitable for flush-mounted installation No Concurrently switching N-neutral Yes

3


2


Additional equipment possible		Yes
Width in number of modular spacings		4
Built-in depth	mm	70.5
Degree of protection (IP)		IP20
Ambient temperature during operating	°C	-25 - 75
Connectable conductor cross section multi-wired	mm²	1 - 25
Connectable conductor cross section solid-core	mm²	1 - 25


Characteristics




Let-through energy I²t According to IEC/EN 60898










Dimensions



Additional product information (links)

AWA1220-1755 Circiut-breaker

AWA1220-1755 Circiut-breaker

ftp://ftp.moeller.net/DOCUMENTATION/AWA_INSTRUCTIONS/17550701.pdf