ENERGY AND AUTOMATION

MOTOR PROTECTION RELAY, PHASE FAILURE / SINGLE PHASE SENSITIVE. THREE POLE **electric** (THREE PHASE), MANUAL RESETTING. DIRECT MOUNTING ON BF40 - BF94 CONTACTORS, 20...33A




Product designation			Motor protection relay
Product type designation			RF82
General characteristics			
Number of poles		nr.	3
Overvoltage category			III
Pollution degree			3
Frontal IP degree			IP20
Type of release			Thermal
Protection fuse			
	gG (IEC)	Α	63 A
	aM (IEC)	Α	40 A
	K5 (UL)	Α	110 A
Phase failure detection			YES
Reset mode			Manual
Power circuit characteristics			
Operating frequency			
	Operational frequency max	Hz	400 1/s
Operating current			
	Operational current min	Α	20 A
	Operational current max	Α	33 A
Tripping class			10A
Test Button			YES
Trip indicator			YES
Terminals			
	type		Yoke clamp
	screw		M5
	tool		Phillips 2
Conductor section			
	AWG max		2
Auxiliary circuit characteristics			
Auxiliary contacts			
	NO	nr.	1
	NC	nr.	1
Operating current AC15			
	24V	Α	3 A
	120V	Α	3 A
	240V	Α	1.5 A
	380V	Α	0.95 A
	480V	Α	0.75 A
	500V	Α	0.72 A
	600V	Α	0.6 A
Operating current DC13			
	125V	Α	0.11 A
	600V	Α	0.22 A

ENERGY AND AUTOMATION


MOTOR PROTECTION RELAY, PHASE FAILURE / SINGLE PHASE SENSITIVE. THREE POLE (THREE PHASE), MANUAL RESETTING. DIRECT MOUNTING ON BF40 - BF94 CONTACTORS, 20...33A

Conventional free air thermal current Ith		Α	10 A
Terminals			
	type		Screw and washer
	screw		M3,5
	tool		Phillips 1
UL/CSA and IEC/EN 60947-5-1 designation			B600-P600
Ambient conditions			
Max altitude		m	3000
Mechanical feautures			
Operating position			
	normal allowable		Vertical plan ±30°
Weight		g	0.365 kg
UL technical data			
Full-load current (FLA) for three-phase AC motor			
	at 480V	Α	33 A
	at 600V	Α	33 A
Dimensions			

Dimensions



Wiring diagrams







ENERGY AND AUTOMATION

MOTOR PROTECTION RELAY, PHASE FAILURE / SINGLE PHASE SENSITIVE. THREE POLE **electric** (THREE PHASE), MANUAL RESETTING. DIRECT MOUNTING ON BF40 - BF94 CONTACTORS, 20...33A

Compliance

CSA C22.2 n° 14 IEC/EN 60947-1 IEC/EN 60947-4-1 **UL508**

Certifications

cULus